



Ref. No.	Date	Time	Location	Construction Noise Level, dB(A)	Parameter	Action Level	Limit Level dB(A)	Follow-up action
X_N002	11-Jan-22	09:30	NMS1 - 1 Tung Wan Tau Road	75.3	Leq(30-min)	when one documented complaint was received.	75	<p>Possible reason: Sheet-piling works at Tung Wan Tau Road</p> <p>Action taken / to be taken: Repeat measurement to confirm result and contractor's sheet-piling shielded by noise insulation sheet was observed in contractor's cofferdam works on landside area. Monitoring was immediately repeated and no exceedance of limit level (57.7dB(A)) was found. According the Event and Action plan, contractor was advised to closely attend to the frequency of sheet-piling action, temporary noise barriers during sheet-piling process.</p> <p>Remarks / Other Obs: Sheet-piling works was conducted at 1 Tung Wan Tau Road during measurement on 11 January 2022. The noise from the sheet-piling was considered as the major noise contribution. As such, the exceedance was considered as project related. Immediate reduction of frequency of sheet-piling action was implemented by contractor and no further exceedance was recorded during repeated measurement such that no further additional monitoring was necessary.</p>